

HVAC TUNE-UP CHECKLIST

WAS THE GAS HEATING CHECKED?

- CO Monitor
- Pilot Condition
- Burner Condition
- Combustion Fan Motor
- Limit and Safety Switches Operation
- Flue Pipe/Vent
- Heat Exchanger
- · Gas Fittings and Shut Off Valve

ELITE MEMBERSHIP BENEFITS

FEATURE BENEFITS	Elite Membership	Regular Pricing
Priority Service		×
Service Response within 48 Hours	>	×
Diagnostic Fee	\$49 /Waived on Repair	\$79
After Hours Diagnostic Fee	\$149 /Waived on Repair	\$300
Service Repairs & Enhancements	15% Off	×
Heating Maintenance	Annual Visit	×
Air Conditioning Maintenance	Annual Visit	×

WAS THE INDOOR UNIT CHECKED?

- · Sec Motor Ctrl Blower
- Circuit Board Condition/Operation
- Blower Wheel Condition/Operation
- Motor Bearings
- Door Switch Operation
- · Condensate Safety Switch Operation
- Evaporator Coil Condition
- Electrical Connections
- Filter Status
- Air Scrubber Operation
- Ducting Condition
- UV/Germicidal Light Operation
- Thermostat Operation
- Attic or Whole House Fan Operation
- Air-flow/Static Pressure
- Condensate Drain Operation

WAS THE OUTDOOR UNIT CHECKED?

- Refrigerant Type
- Refrigerant Pressures High & Low Side
- Super Heat and Sub-Cool Readings
- Sec. Motor Ctrl Compressor
- Sec. Motor Ctrl Fan Motor
- Outdoor Coil Condition
- Primary Motor Control Condition
- Surge Protector
- Compressor Saver Operation
- Fan Motor Condition and Operation
- Disconnect and Fuse Condition

